

Advisory regarding submission of CON-4/ Technical Connection data by Applicant (RE Generators)

The RE Generators shall observe the explanations, procedures, timelines and furnish the Test/Study reports as contained in the **“Report of the Working Group in respect of Data Submission Procedure and Verification of Compliance to CEA Regulations on Technical Standards for Connectivity to the Grid by RE Generators”** (available at CTU website) in respect of submission of CON-4 documents/Technical Connection Data and demonstration of compliance to CEA Regulations on Technical Standards for Connectivity to the Grid.

1. The RE generator shall submit the complete CON-4/Technical connection data at least 12 months prior to the physical interconnection with the Grid in line with the above-mentioned Working Group Report with the undertaking that the data/RE plant model submitted is accurate and representative of the actual plant response.
2. Based on the submitted data/RE plant model and the studies carried out by applicant, the RE generator shall take advance action for the implementation of the required measures towards compliance with CEA Regulations on Technical Standards for Connectivity to the Grid, pending issuance of CON-5 upon fulfilment of all applicable compliances by applicant.
3. After obtaining Connection Offer (CON-5), if there is any deviation in the compliance requirement vis a vis earlier planned measures in Para (2) above, the grantee shall take necessary timely actions (as per the Working Group Report) in this regard.