



भा रत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली योजना एवं मूल्यांकन प्रभाग-II
Power System Planning & Appraisal Division-II

सेवा में / To

Chief Operating Officer, CTUIL
 Floors Nos. 5-10, Tower 1, Plot Nos. 16,
 IRCON International Tower, Institutional Area,
 Sector 32, Gurugram, Haryana – 122001

विषय: एनसीटी द्वारा **30.12.2025** को आयोजित **36वीं बैठक** में अनुमोदित आईएसटीएस ट्रांसमिशन/संचार योजनाओं का कार्यान्वयन- के बारे में

Subject: Implementation of ISTS Transmission/Communication Schemes approved by NCT in 36th meeting held on 30.12.2025- regarding

महोदय/Sir,

The undersigned is directed to inform that in the 36th meeting of NCT held on 30.12.2025, it was decided to delink the scope of “Creation of 400 kV switchyard along with Installation of 2x1500 MVA, 765/400 kV ICTs at Vataman (AIS) with 2x125 MVar (420 kV) Bus Reactors” from “Transmission system for offshore wind zone phase -1 (500 MW VGF off coast of Gujarat for subzone B3)” and continue implementation of the below stated scope of works with revised scheme name as **‘Transmission System for reliable power supply to Dholera area’** without any change to the implementation time-frame:

Sl. No.	Scope of Transmission Scheme	Implementation timeframe	Estimated Cost (₹ Cr)
1.	<p>Creation of 400 kV switchyard along with Installation of 2x1500 MVA, 765/400 kV ICTs at Vataman (AIS) with 2x125 MVar (420 kV) Bus Reactors</p> <ul style="list-style-type: none"> • 765/400 kV, 1500 MVA, ICTs – 2 Nos. (7x500MVA incl. spare unit) • 765 kV ICT bays – 2 nos. • 400 kV ICT bays – 2 nos. • 125 MVAR, 420 kV Bus Reactor – 2 Nos. • 400 kV Bus Reactor Bay – 2 Nos. 	18 months from CTU letter dated 02.09.2024 to POWERGRID.	308

This is for information and further necessary action please.

भवदीय / Yours faithfully,

(बी.एस.बैरवा/ B.S.Bairwa)

मुख्य अभियन्ता एवं सदस्य सचिव, एन.सी.टी./
Chief Engineer & Member Secretary (NCT)

Copy to:

Joint Secretary (Trans), Ministry of Power, Shram Shakti Bhawan, New Delhi-110001