

Status of margins available at existing ISTS substations (non RE) for proposed RE integration												All figures are in MW (as on 30-04-2023)	
Name of station	Transformation Capacity (MVA)						Capacity Allocated (MW)	Additional Margin on existing / UC system		Additional Margin with ICT Augmentation		No. of Trfs required for RE integration	Remarks
	Existing		Under Implementation		Planned			220kV level	400kV level	220kV level	400kV level		
	765/400kV	400/220kV or 400/132kV	765/400kV	400/220kV	765/400kV	400/220kV							
<b>Gujarat</b>													
Pirana 400/220kV		2x315MVA, 400/220kV					0	300	0	0	0	0	400kV & 220kV overloading.
							<b>Total GUJ:</b>	<b>300</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>300</b>
<b>Maharashtra</b>													
Solapur 765/400/220kV	2x1500MVA, 765/400kV	2x315MVA+1x500MVA, 400/220kV					476	0	1024	0	0	0	<ul style="list-style-type: none"> <li>Presently, 258MW capacity has been allocated at 400kV level &amp; 218MW is under process. Balance 1024MW margin is left at 400kV level.</li> <li>Further, Solapur PP for 1.5GW potential has been planned alongwith Solapur PP - Solapur (PG) 400 kV D/c line (twin HTLS), for which 2 bays has been reserved at Solapur (PG).</li> <li>No margin for injection at 220kV level as overloading in 220kV downstream network.</li> </ul>
Aurangabad 765/400/220kV	2x1500MVA, 765/400kV	2x315MVA, 400/220kV					0	0	1000	0	0	0	Overloading in 220kV downstream network.
Kolhapur 400kV							0	0	0	0	0	0	Overloading observed in 400kV Kolhapur (PG)-Kolhapur(MSETCL) D/c line.
Parli (PG) 400/220kV		2x500MVA, 400/220kV					300	0	0	0	0	0	300MW capacity has been allocated at Parli (PG) S/s. Overloading in 220kV downstream & Parli 400kV network.
Parli (New) 765/400kV	2x1500MVA, 765/400kV						300	0	400	0	0	0	277MW capacity has been allocated at Parli (New) S/s & 23MW is under process at 400kV level and accordingly balance 400MW margin is left at 400kV level out of 700MW.
							<b>Total MAH:</b>	<b>0</b>	<b>2424</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>2424</b>
<b>Madhya Pradesh</b>													
Khandwa 400/220kV		2x315+1x500MVA, 400/220kV					300	0	0	0	0	0	300MW Stage-II connectivity & 300MW LTA from Masaya Solar at Khandwa has also been granted. Overloading in 220kV downstream network.
Indore 765/400/220kV	2x1500MVA, 765/400kV	2x500MVA, 400/220kV + (1x500MVA with sectionalisation at 220kV for RE injection)					324.4	150	0	0	0	0	500MVA, 400/220kV ICT has been approved in the 2nd WRPC(TP) meeting and all the works have been completed. 324.4MW LTA has been granted on this ICT and balance 150MW margin is left on the ICT. Overloading in 220kV downstream network.

Status of margins available at existing ISTS substations (non RE) for proposed RE integration													All figures are in MW (as on 30-04-2023)
Name of station	Transformation Capacity (MVA)						Capacity Allocated (MW)	Additional Margin on existing / UC system		Additional Margin with ICT Augmentation		No. of Trfs required for RE integration	Remarks
	Existing		Under Implementation		Planned			220kV level	400kV level	220kV level	400kV level		
	765/400kV	400/220kV or 400/132kV	765/400kV	400/220kV	765/400kV	400/220kV							
Jabalpur PS 765/400	2x1500MVA, 765/400kV						0	0	1000	0	0	0	765/400kV ICT overloading.
Seoni 765/400/220kV	3x1500MVA, 765/400kV	2x315MVA + 1x500MVA 400/220kV					0	0	0	0	0	0	Overloading in 220kV downstream network.
Rajgarh 400/220kV		2x315MVA, 400/220kV		1x500MVA, 400/220kV with sectionalisation at 220kV for RE injection			257	43	0	209.8	0	1	St-II Connectivity of 156.24MW has been granted to Sprng Vayu Vidyut Pvt Ltd.at Rajgarh S/s (Existing) & 100.8MW in under process. Overloading in 220kV downstream network. Further, St-II Connectivity of 190.2MW has been granted to VEH Jayin Renewables Private Limited through 400/220kV, 500MVA ICT sectionalised at 220kV for RE injection as agreed in 10th CMETS WR held on 30.08.2022 & 75MW is under process.
Satna 765/400/220kV	2x1000MVA, 765/400kV	2x315+1x500MVA, 400/220kV		1x500MVA, 400/220kV			0	0	0	0	0	0	Overloading in 220kV downstream network.
							<b>Total MP:</b>	<b>192.96</b>	<b>1000</b>	<b>209.8</b>	<b>0</b>	<b>1</b>	<b>1402.76</b>
<b>Chhattisgarh</b>													
Dharamjaygarh 765/400kV	2x1500MVA 765/400kV						0	0	900	0	0	0	765/400kV ICT overloading.
Champa 765/400kV	6x1500MVA 765/400kV						0	0	1500	0	0	0	765/400kV ICT overloading.
Bilaspur PS 765/400kV	3x1500MVA 765/400kV						0	0	1000	0	0	0	765/400kV ICT overloading.
							<b>Total Chhat:</b>	<b>0</b>	<b>3400</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>3400</b>
							<b>Total WR</b>	<b>492.96</b>	<b>6824</b>	<b>209.8</b>	<b>0</b>	<b>1</b>	<b>7526.76</b>
<b>Andhra Pradesh</b>													
Kurnool (New) 765/400kV	2X1500 MVA, 765/400 kV						1725	0	240	0	1000	1	Additional margin is with the availability of Kurnool New - Maheshwaram 765kV D/c corridor. LTA of 1465 MW has been granted with Narendra-Pune 765kV D/c line which is expected by Jul'24 (considering SPV transfer by Jan, 2023).
							<b>Total AP:</b>	<b>0</b>	<b>240</b>	<b>0</b>	<b>1000</b>	<b>1</b>	<b>1240</b>
<b>Karnataka</b>													
Hiriyur 400/220kV		2x315 MVA + 1x500 MVA, 400/220 kV					366	234	0	0	0	0	LTA of 300 MW granted at Hiriyur.
							<b>Total Kar:</b>	<b>234</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>234</b>
<b>Kerala</b>													
Palakkad (400/220kV)		2x315 MVA + 1x500 MVA, 400/220 kV					0	300	0	0	0	0	
							<b>Total Ker:</b>	<b>300</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>300</b>
<b>Tamil Nadu</b>													

**Status of margins available at existing ISTS substations (non RE) for proposed RE integration**

*All figures are in MW (as on 30-04-2023)*

Name of station	Transformation Capacity (MVA)						Capacity Allocated (MW)	Additional Margin on existing / UC system		Additional Margin with ICT Augmentation		No. of Trfs required for RE integration	Remarks
	Existing		Under Implementation		Planned			220kV level	400kV level	220kV level	400kV level		
	765/400kV	400/220kV or 400/132kV	765/400kV	400/220kV	765/400kV	400/220kV							
Pugalur(Existing) 400/230kV		2x315 MVA + 1x500 MVA, 400/230 kV					300	300	0	0	0	0	
Malekottaiyur(Kalive ndapattu) 400/230kV		2x315 MVA + 1x500 MVA, 400/230 kV					NIL	500	0	0	0	0	
Nagapattinam PS 765/400kV	Charged at 400 kV						NIL	0	1000	0	0	0	
							<b>Total TN:</b>	<b>800</b>	<b>1000</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1800</b>
							<b>Total SR</b>	<b>1334</b>	<b>1240</b>	<b>0</b>	<b>1000</b>	<b>1</b>	<b>3574</b>
<b>Rajasthan</b>													
Chittorgarh 765/400kV	765/400kV : 2x1500MVA						NIL	0	0	0	0	0	
Ajmer 765/400kV	765/400kV : 2x1500MVA						NIL	0	0	0	0	0	
Bassi		400/220 kV : 2x315MVA +1x500MVA					NIL	0	0	0	0	0	220kV overloading
Bhiwadi		400/220 kV : 3x315MVA					NIL	0	0	0	0	0	220kV overloading
Kankroli		400/220 kV : 3x315MVA					NIL	0	0	0	0	0	220kV overloading
Kota		400/220 kV : 2x315MVA					NIL	0	0	0	0	0	220kV overloading
Bhinmal		400/220 kV : 2x315MVA		400/220 kV : 1x315MVA			NIL	0	0	0	0	0	
Neemarana		400/220 kV : 1x315MVA +1x500MVA					NIL	300	0	0	0	0	
Sikar		400/220 kV : 2x315MVA +1x500MVA					NIL	0	0	0	0	0	220kV overloading
Jaipur (South)		400/220 kV : 2x500MVA					NIL	400	0	0	0	0	
Kotputli		400/220 kV : 2x315MVA			400/220 kV : 1x500MVA		NIL	150	0	0	0	0	
							<b>Total RAJ</b>	<b>850</b>	<b>350</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>1200</b>
<b>Haryana</b>													
Kaithal		400/220 kV : 3x315MVA					NIL	150	0	0	0	0	
Panchkula		400/220 kV : 2x315MVA+500MVA					NIL	0	0	500	0	1	
Bahadurgarh		400/220 kV : 315MVA +500MVA		400/220 kV : 1x500MVA			NIL	150	0	0	0	0	
Sonepat		400/220 kV : 2x315MVA					NIL	0	0	500	0	1	
Manesar		400/220 kV : 2x500MVA					NIL	250	0	0	0	0	
							<b>Total HARY</b>	<b>550</b>	<b>0</b>	<b>1000</b>	<b>0</b>	<b>2</b>	<b>1550</b>

**Status of margins available at existing ISTS substations (non RE) for proposed RE integration**

*All figures are in MW (as on 30-04-2023)*

Name of station	Transformation Capacity (MVA)						Capacity Allocated (MW)	Additional Margin on existing / UC system		Additional Margin with ICT Augmentation		No. of Trfs required for RE integration	Remarks
	Existing		Under Implementation		Planned			220kV level	400kV level	220kV level	400kV level		
	765/400kV	400/220kV or 400/132kV	765/400kV	400/220kV	765/400kV	400/220kV							
<b>Uttar Pradesh</b>													
Kanpur(New)	765/400 kV : 2x1500MVA				1x1500		NIL	0	1250	0	0	0	220kV Not available
Fatehpur	765/400kV : 2x1500MVA;	400/220 kV : 2X315MVA					NIL	0	0	500	0	1	
Mainpuri		400/220 kV : 2x315MVA +500MVA					NIL	150	0	0	0	0	
Sohawal		400/220 kV : 2x315MVA		400/220 kV : 1X500MVA			NIL	100	0	0	0	0	
Lucknow (new)	765/400 kV : 2x1500MVA						NIL	0	500	0	0	0	
Balia	765/400 kV : 2x1500MVA						NIL	0	850	0	0	0	220kV Not available.
Bareilly(New)	765/400 kV : 2x1500MVA						NIL	0	500	0	0	0	
Varanasi	765/400 kV : 2x1500MVA						NIL	0	500	0	0	0	
							<b>Total UP</b>	<b>250</b>	<b>3600</b>	<b>500</b>	<b>0</b>	<b>1</b>	<b>4350</b>
							<b>Total NR</b>	<b>1650</b>	<b>3950</b>	<b>1500</b>	<b>0</b>	<b>3</b>	<b>7100</b>
<b>Odisha</b>													
Jeypore		2x630MVA (400/220kV)						500	0	0	0	0	
Keonjhar		2x315MVA (400/220kV)					0	300	0	0	0	0	
Pandiabil		2x500MVA (400/220kV)					0	400	0	0	0	0	
Rengali		2x315MVA (400/220kV)					0	100	0	0	0	0	
Angul	4x1500MVA						0	0	2500	0	0	0	
<b>Total</b>							<b>Total Od:</b>	<b>1300</b>	<b>2500</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>3800</b>
<b>Jharkhand</b>													
Chaibasa		2x315MVA (400/220kV)					0	400	0	0	0	0	
Daltonganj		2x315MVA (400/220kV)					0	400	0	0	0	0	
Ranchi		2x315MVA (400/220kV)		1x315MVA				800		400	0	0	Additional 400MW would be available after commissioning of 3rd 400/220kV, 500MVA ICT at Ranchi (expected by Feb 2023)
Ranchi (New)	2x1500MVA						0	0	900	0	0	0	
Chandwa	-	-	-	-	-	-		0	900	0	0	0	
Dhanbad		2x500MVA (400/220kV)						300					
<b>Total</b>							<b>Total Jh:</b>	<b>1900</b>	<b>1800</b>	<b>400</b>	<b>0</b>	<b>0</b>	<b>4100</b>
<b>Bihar</b>													

**Status of margins available at existing ISTS substations (non RE) for proposed RE integration**

*All figures are in MW (as on 30-04-2023)*

Name of station	Transformation Capacity (MVA)						Capacity Allocated (MW)	Additional Margin on existing / UC system		Additional Margin with ICT Augmentation		No. of Trfs required for RE integration	Remarks
	Existing		Under Implementation		Planned			220kV level	400kV level	220kV level	400kV level		
	765/400kV	400/220kV or 400/132kV	765/400kV	400/220kV	765/400kV	400/220kV							
Banka		2x200MVA + 1x315MVA (400/132kV)		2x500MVA (400/220kV)			0	100	0	400	0	0	100MW at 132kV level in the existing system and 400MW at 220kV level with the implementation of "Augmentation of 400/220kV, 2x500MVA ICT at Banka" Scheme expected by Oct 2024
Lakhisarai		2x200MVA + 1x315MVA (400/132kV)					0	200	0	0	0	0	132kV level
Motihari		2x200MVA + 1x315MVA (400/132kV)					0	500	0	0	0	0	132kV level
Chandauti		3x500MVA (400/220kV)					0	900	0	0	0	0	
Muzaffarpur		2x315MVA + 1x500MVA (400/220kV)					0	600	0	0	0	0	line corridor available for 2 lines
Saharsa		2x500MVA (400/220kV)					0	900	0	0	0	0	
Sitamarhi		2x500MVA (400/220kV)					0	900	0	0	0	0	
							<b>Total Bihar:</b>	<b>4100</b>	<b>0</b>	<b>400</b>	<b>0</b>	<b>0</b>	<b>4500</b>
<b>West Bengal</b>													
Durgapur-B		3x315MVA (400/220kV)						0		300			220kV overloaded in present case under N-1. 300MW margin would be created after reconductoring of Durgapur - Parulia 220kV D/c line by DVC
Maithon-B		3x500MVA (400/220kV)						300					
Subhasgram		2x315MVA + 1x500MVA (400/220kV)					0	600	0	300	0	0	Additional 300MW would be available after commissioning of 6th 400/220kV, 500MVA ICT at Subhasgram by CESC (expected by 2024)
Jeerat-New	2x1500MVA						0	0	2400	0	0	0	
Medinipur	2x1500MVA						0	0	1500	0	0	0	
							<b>Total WB:</b>	<b>900</b>	<b>3900</b>	<b>600</b>	<b>0</b>	<b>0</b>	<b>5400</b>
							<b>ER-Total</b>	<b>8200</b>	<b>8200</b>	<b>1400</b>	<b>0</b>	<b>0</b>	<b>17800</b>

<b>All India Total</b>	<b>11676.96</b>	<b>20214</b>	<b>3109.8</b>	<b>1000</b>	<b>5</b>	<b>36000.8</b>
------------------------	-----------------	--------------	---------------	-------------	----------	----------------

**Disclaimer**

The margins indicated at the existing ISTS substation may vary depending on network topology, Load-Generation balance, etc.

Status of margins available at Existing / Under Construction / Planned ISTS RE Pooling Stations for proposed RE integration														All figures are in MW (as on 30-04-2023)		
Name of station	Region	RE PS Category	State	Transformation Capacity (MVA)						Pooling station capacity (MVA)	Capacity Allocated (MW)	Additional Margin on existing / UC system		Additional Margin with Planned/Future ICT/Line Augmentation		Remarks
				Existing		Under Implementation		Planned [Approved/Under Approval]				220kV level	400kV level	220kV level	400kV level	
				765/400kV	400/220kV	765/400kV	400/220kV	765/400kV	400/220kV							
Bhadla 765/400/220kV	NR	GEC-II & 66.5 GW REZ	Rajasthan	3x1500	8x500					3580	3580					No further margin available
Bikaner 765/400/220kV	NR	66.5 GW REZ & Beyond	Rajasthan	2x1500	2x500	1x1500	1x500	1x1500		4825	3875				950	No further margin available for connectivity. 3275MW LTA has been granted at Bikaner PS. Power flow is being influenced by LTA at Bikaner-II also. 600MW margin available with planned 1x1500MVA, 765/400kV ICT (3rd) at Bikaner PS along with part of Phase-II system (Bikaner-II & onwards). Enhancement margins of 950MW (400kV) may require additional corridors beyond Bikaner-II PS/Bikaner-III PS. Bikaner-III PS and onwards system is approved in NCT (24 months schedule) [expected Schedule-Jul'25]
Fatehgarh Pool (400kV)	NR	GEC-II & 66.5 GW REZ	Rajasthan							2200	2200					No further margin available
Bhadla-II 765/400/220kV	NR	66.5 GW REZ & Beyond	Rajasthan	3x1500	4x500	1x1500	4x500	1x1500		5945	5945					No further margin available for connectivity. LTA of 4245MW is granted/received at Bhadla-II PS. Margin available may be evacuated with under implementation Phase-II system and part of Phase-II scheme incl. 1x1500MVA, 765/400kV ICT (5th) at Bhadla-II which is envisaged by Dec'24 (tentative). No further margin is available for power evacuation.
Fatehgarh-II 765/400/220kV	NR	66.5 GW REZ & Beyond	Rajasthan	4x1500	8x500	2x1500	1x500		2x500	5460	5460					No further margin available for connectivity. LTA of 5110MW is granted at Fatehgarh-II PS. Margin available for 350MW LTA (at 220kV level) is with 1x500MVA, 400/220kV ICT (10th) at Fatehgarh-II i.e. part of Phase-III system which is by Dec'24 (tentative). No further margin is available for power evacuation.
Bikaner-II 400/220kV	NR	66.5 GW REZ & Beyond	Rajasthan				2x500		5x500	5460	5460					No further margin available for connectivity. 2492 MW LTA is already received/granted at Bikaner-II PS. Recently 765/400kV ICT (4th) at Bikaner is awarded which can also accommodate LTA at Bikaner-II PS upto 2900 MW. For power evacuation from Bikaner-II, Power flow is being influenced by LTA at Bikaner also. For LTA quantum >2900 MW at Bikaner-II PS, additional corridors beyond Bikaner-III PS along with 400/220kV Bikaner-II ICTs (5x500MVA) is required. Bikaner-III PS and onwards system is approved by MOP (24 months schedule) [expected Schedule-Jul'25]. Recently, St-II connectivity granted to M/s SOLTOWN (675MW) has been revoked. After this, 675MW margin is available for grant at Bikaner-II PS which may be allotted to other RE developers based on their application/consent for GNA Transition.
Fatehgarh-III Section-I (erstwhile Ramgarh-II) 400/220kV	NR	66.5 GW REZ & Beyond	Rajasthan				4x500		1x500	2280	2280					No further margin available for connectivity. 2280 MW Connectivity and 1980MW LTA has already been granted at 220kV level at Fatehgarh-III one section. 1980MW LTA may be evacuated is with Phase-II system. Additional 300MW LTA (beyond 1980 MW) can be evacuated based on transformer augmentation in Ph-III subject to approval. M/s Adani vide letter dtd 21/03/23 submitted their dissent for GNA transition for their 1500MW solar project in Fatehgarh-III PS (300MW at Sec-I) as per CERC (Connectivity & GNA to the ISTS) regulation 2022. However upon completion of GNA Transition process, vacated margins shall be declared.
Fatehgarh-III Section-II 765/400/220kV	NR	66.5 GW REZ & Beyond	Rajasthan					6x1500	5x500	5525	5525					No further margin available for connectivity. 4233MW LTA has been received/granted at Fatehgarh-III (Section-II). Margin available for LTA is with Phase-III scheme incl. 6x1500MVA, 765/400kV ICTs at Fatehgarh-III. Phase-III system is under bidding & envisaged by Dec'24 (tentative). M/s Adani vide letter dtd 21/03/23 submitted their dissent for GNA transition for their 1500MW solar project in Fatehgarh-III PS (1200MW at Sec-II) as per CERC (Connectivity & GNA to the ISTS) regulation 2022. However upon completion of GNA Transition process, vacated margins shall be declared.

Status of margins available at Existing / Under Construction / Planned ISTS RE Pooling Stations for proposed RE integration														All figures are in MW (as on 30-04-2023)		
Name of station	Region	RE PS Category	State	Transformation Capacity (MVA)						Pooling station capacity (MVA)	Capacity Allocated (MW)	Additional Margin on existing / UC system		Additional Margin with Planned/Future ICT/Line Augmentation		Remarks
				Existing		Under Implementation		Planned [Approved/Under Approval]				220kV level	400kV level	220kV level	400kV level	
				765/400kV	400/220kV	765/400kV	400/220kV	765/400kV	400/220kV							
Bhadla-III 765/400/220kV	NR	Beyond 66.5GW	Rajasthan					2x1500	10X500	6500	2950	2550	1000			Connectivity Margins at Bhadla-III PS (Expected Schedule-Dec'24) is available for about balance 3.55GW (Out of 6.5GW potential). LTA of 950MW already received at Bhadla-III PS. For power evacuation from Bhadla-III, about 2600MW LTA is already granted (Ramgarh applicant). M/s Adani vide letter dtd 22/02/23 submitted their dissent for GNA transition for their 1500MW solar project in Ramgarh PS as per CERC (Connectivity & GNA to the ISTS) regulation 2022. For power evacuation beyond Bhadla-III, 6 GW HVDC system (Bhadla-Fatehpur) under Ph-III will be required which is approved by MOP (with 42 months schedule) [expected by Dec'26]. However upon completion of GNA Transition process, vacated margins shall be declared.
Fatehgarh-IV (Section-1 400/220kV)	NR	Beyond 66.5GW	Rajasthan						5X500	2060	2060					No further margin available for connectivity in Section-1. 730MW LTA has been received/granted at 220kV level for evacuation with Raj Ph-III scheme. Evacuation Margin available for additional 1330MW with Phase-III scheme. Phase-III system is under bidding & envisaged by Dec'24 (tentative). For evacuation of power beyond 1330MW, additional transmission system from Fatehgarh-IV (Section-2) is already evolved and under approval with NCT (for evacuation capacity of about 4 GW) [expected schedule by Nov'25]
Ramgarh 765/400/220kV	NR	Beyond 66.5GW	Rajasthan					3x1500	2X500	7500	2750			300	250	For power evacuation from Ramgarh (through Ramgarh-Bhadla-III), about 2600MW LTA is already granted (Ramgarh applicant). For power evacuation beyond Bhadla-III, 6 GW HVDC system (Bhadla-Fatehpur) under Ph-III will be required which is approved by MOP (with 42 months schedule) [expected by Dec'26]. For power evacuation of about 2 GW potential (beyond 2900MW) at Ramgarh, system is under approval. M/s Adani vide letter dtd 22/02/23 submitted their dissent for GNA transition for their 1500MW solar project in Ramgarh PS as per CERC (Connectivity & GNA to the ISTS) regulation 2022. However upon completion of GNA Transition process, vacated margins shall be declared.
Bikaner-III 765/400/220kV	NR	Beyond 66.5GW	Rajasthan					6X1500	5x500	4000	617	1383	2000			617MW St-II has been received/granted at 220kV level. For power evacuation, Bikaner-III PS and onwards transmission system along with 765/400kV Bikaner ICT is required which is approved by MOP (with 24 months schedule) [expected Schedule-Jul'25]
NP Kunta 400/220kV	SR	NP Kunta UMSP	Andhra Pradesh		4x500 MVA, 400/220 kV					2000	1500	300	0	0	0	
Pavagada 400/220kV	SR	Tumkur (Pavagada) UMSP	Karnataka		5x500 MVA, 400/220 kV		1x500 MVA, 400/220 kV			3000	3050	0	0	0	0	Connectivity of 3050 MW granted at Pavagada PS. Pavagada PS has been closed for all purpose regarding grant of Connectivity at 220kV level.
Tuticorin-II GIS (erstwhile Tirunelveli) (PG) 400/230kV)	SR	GEC-I	Tamil Nadu		3x500 MVA, 400/230 kV		2x500 MVA, 400/230 kV			2500	2220.1	154.9	0	475	0	Connectivity of 2220.1 MW and LTA of 2170.1 MW has been granted at Tuticorin-II GIS. Power transfer from Tuticorin upto 1870 MW has been considered through existing/under implementation system. However for transfer of additional quantum from Tuticorin-II GIS to NEW grid shall require Narendrapur-675kV D/c line which is expected by Jul'24. 230kV line bay is not available for allocation for grant of Connectivity for injection of power. However, margins available in the already allocated line bays may be utilized for grant of Connectivity through sharing of dedicated infrastructure.

Status of margins available at Existing / Under Construction / Planned ISTS RE Pooling Stations for proposed RE integration														All figures are in MW (as on 30-04-2023)		
Name of station	Region	RE PS Category	State	Transformation Capacity (MVA)						Pooling station capacity (MVA)	Capacity Allocated (MW)	Additional Margin on existing / UC system		Additional Margin with Planned/Future ICT/Line Augmentation		Remarks
				Existing		Under Implementation		Planned [Approved/Under Approval]				220kV level	400kV level	220kV level	400kV level	
				765/400kV	400/220kV	765/400kV	400/220kV	765/400kV	400/220kV							
Koppal PS 400/220kV	SR	66.5 GW REZ	Karnataka				5x500MVA, 400/220kV			2500	2753.6	0	0	0	0	Koppal PS has been closed for all purpose regarding grant of Connectivity. LTA of 1740 MW has been granted/agreed for grant at Koppal PS. Power transfer beyond 1200 MW from Koppal PS towards NEW Grid shall require Narendra-Pune 765kV D/c line which is expected by Jul'24.
Gadag PS 400/220kV	SR	66.5 GW REZ	Karnataka				5x500MVA, 400/220kV			2500	2435	0	0	0	0	Gadag PS has been closed for all purposes regarding grant of Connectivity. LTA of 1110 MW has been granted/agreed for grant at Gadag PS. Power transfer is being influenced by RE generations at Koppal PS also. Further power transfer beyond 360 MW from Gadag PS towards NEW Grid shall require Narendra-Pune 765kV D/c line which is expected by Jul'24.
Karur PS 400/230kV	SR	66.5 GW REZ	Tamil Nadu				2x500 MVA, 400/230 kV		3x500 MVA, 400/230 kV	2500	420	580	0	1500	0	LTA of 420 MW has been granted at Karur PS with Narendra-Pune 765kV D/c line which is expected by Jul'24.
Kurnool-III PS 765/400/220kV	SR	66.5 GW REZ	Andhra Pradesh			3x1500MVA, 765/400kV	9x500MVA, 400/220kV			4500	0	4500	0	0	0	Kurnool-III PS and associated transmission system is under implementation and expected by Nov'24.
Ananthapuram PS 400/220kV	SR	66.5 GW REZ	Andhra Pradesh				7x500MVA, 400/220kV			3500	0	3500	0	0	0	Ananthapuram PS and associated transmission system is under bidding stage.
Bidar PS 765/400/220kV	SR	66.5 GW REZ	Karnataka			3x1500MVA, 765/400kV	5x500MVA, 400/220kV			2500	0	2500	0	0	0	Bidar PS and associated transmission system is under bidding stage.
Koppal-II PS 765/400/220kV	SR	181.5 GW REZ	Karnataka					2x1500MVA, 765/400kV	4x500MVA, 400/220kV	2000	485	1515	0	0	0	Pooling Station has been identified considering 1000 MW of BESS and Koppal-II PS & associated transmission system is under bidding stage.
Gadag-II PS 400/220kV	SR	181.5 GW REZ	Karnataka						4x500MVA, 400/220kV	2000	830	1170	0	0	0	Pooling Station has been identified considering 1000 MW of BESS and Gadag-II PS & associated transmission system is under bidding stage.
Bhuj PS	WR	GEC-I	Gujarat	4x1500MVA, 765/400kV	8x500MVA, 400/220kV				1x500MVA, 400/220kV	4500	3366	634		500		Bhuj PS has been planned for evacuation of 4.5GW power from generation projects. Presently, 3366MW capacity has been allocated at Bhuj PS. Additional margin of 634MW is available with Bhuj-II-Lakadia-Vadodara765kV corridor which has been commissioned.  Further, with additional 9th 400/220kV ICT at Bhuj PS, additional 500MW can be evacuated beyond 4000MW in case of injection at 220kV level. Above margin can also be availed at 400kV level upon requirement.  In meeting held under the chairmanship of Secretary (Power) on 11.01.2023, as no RE generation is expected in Bhuj, it was decided to drop the 9th ICT augmentation scheme for 0.5GW potential.
Radhanesda PS 400/220kV	WR	GEC-II	Gujarat		2x500MVA, 400/220kV					1000	700	250				700MW capacity has been allocated to GPCL at Radhanesda. With availability of Bhuj-II-Lakadia-Vadodara765kV corridor which has been commissioned, 250MW margin is available on existing 2x500MVA, 400/220kV ICTs and Radhanesda-Banaskantha 400kV D/c line (Twin AL-59).
Jam Khambhaliya PS 400/220kV	WR	66.5 GW REZ	Gujarat		4x500MVA, 400/220kV					2000	469.4	730.6				Presently, 416.4MW capacity has been allocated at Jam Khambhaliya PS (excluding Vaayu Mevasa who has filed Petition No. 20/MP/2021 along with IA No.29/2021 for relinquishment & Airpower whose connectivity has been revoked) & 53MW of POWERICA is under process. 730.6MW margin is available as total 1200MW can be evacuated from Jam Khambhaliya (GIS) PS. Above margin can also be availed at 400kV level upon requirement.
Bhuj-II PS 765/400/220kV	WR	66.5 GW REZ	Gujarat	2x1500MVA, 765/400kV	4x500MVA, 400/220kV					2000	1048.5	951.5				Bhuj-II PS has been planned for evacuation of 2GW power from generation projects. Presently, 1048.5MW capacity has been allocated at Bhuj-II PS. With the availability of Bhuj-II-Lakadia-Vadodara765kV corridor which has been commissioned, additional margin of 951.5MW is available. Above margin can also be availed at 400kV level upon requirement.



Status of margins available at Existing / Under Construction / Planned ISTS RE Pooling Stations for proposed RE integration														All figures are in MW (as on 30-04-2023)		
Name of station	Region	RE PS Category	State	Transformation Capacity (MVA)						Pooling station capacity (MVA)	Capacity Allocated (MW)	Additional Margin on existing / UC system		Additional Margin with Planned/Future ICT/Line Augmentation		Remarks
				Existing		Under Implementation		Planned [Approved/Under Approval]				220kV level	400kV level	220kV level	400kV level	
				765/400kV	400/220kV	765/400kV	400/220kV	765/400kV	400/220kV							
Lakadia PS	WR	66.5 GW REZ	Gujarat	2x1500MVA, 765/400					4x500MVA, 400/220kV	2000	0			2000	Lakadia PS has been planned for evacuation of 2GW power from generation projects. In meeting held under the chairmanship of Secretary (Power) on 11.01.2023, as no RE generation is expected in Lakadia, it was decided to drop the ISTS schemes for Lakadia (2GW).	
Khavda I PS (9GW)	WR	66.5 GW REZ and beyond	Gujarat			3x1500MVA, 765/400kV			4x1500MVA, 765/400kV (Under Bidding) 1x1500MVA, 765/400kV (Planned)	9000	9000				Ph-1: 3GW transmission system under implementation with schedule as Jan'24. Ph-2: 5GW transmission system has been awarded with implementation schedule of Mar'25. Ph-3: 7GW transmission system is under bidding with implementation schedule as 24 months from SPV transfer. Ph-4: 7GW transmission system has been planned & being taken up in ensuing NCT meeting. Ph-5: 8GW transmission system has been planned being taken up in ensuing NCT meeting. Presently, 30GW system has been planned for evacuation of power from generation projects at Khavda and the same is expected to be progressively commissioned from Jan'24 to Mar'27. At present, 10.8GW margin is available.	
Khavda II PS (9.3GW)	WR	66.5 GW REZ and beyond	Gujarat			4x1500MVA, 765/400 kV			5x1500MVA, 765/400kV	10500	3755					
Khavda III PS (7.6GW)	WR	66.5 GW REZ and beyond	Gujarat			3x1500MVA, 765/400 kV			4x1500MVA, 765/400kV	7500	6450					
Solapur PS (1.5GW)	WR	66.5 GW REZ	Maharashtra						4x500MVA, 400/220kV	1500	460			1040	Solapur PS has been planned for evacuation of 1.5GW power from generation projects and has been agreed in NCT meeting. Presently, 260MW capacity has been allocated at Solapur PS at 220kV level & 200MW is under process and accordingly balance 1040MW margin is left.	
Wardha PS	WR	66.5 GW REZ	Maharashtra						5x500MVA, 400/220kV	2500				2500	Wardha PS has been planned for evacuation of 2.5GW power from generation projects. In meeting under the chairmanship of Secretary (Power) on 11.01.2023, as no RE generation is expected in Wardha it was decided to drop the ISTS schemes for Wardha (PP) (2.5GW).	
Kallam PS	WR	66.5 GW REZ :1GW 181.5GW: 1GW	Maharashtra				4x500MVA, 400/220kV			2000	1921.6				Presently, 1922MW capacity has been allocated at Kallam PS at 220kV level and 66MW at 400kV level & 92MW is under process. No margin is available at 220kV level at Kallam PS. Transmission system for evacuation of 1GW power is under implementation and is expected by Oct'23 and 1GW scheme augmentation scheme is expected by May'24.	
Pachora PS (near Agar)	WR	66.5 GW REZ	MP				3x500MVA, 400/220kV		3x500MVA, 400/220kV	2500	1000	500		1000	Pachora PS has been planned for evacuation of 2500MW power from generation projects. Pachora Ph-1 (1.5GW) system is under implementation with schedule as progressively by Nov'23 and Pachora Ph-2 (1GW) has been planned. Presently, 1000MW capacity has been allocated at Pachora PS and 1500MW margin is left.	
Chhatarpur PS	WR	66.5 GW REZ	MP						3x500MVA, 400/220kV (Under Bidding)	1500	0			1500	Chhatarpur PS has been planned for evacuation of 1500MW power from generation projects. Chhatarpur PS and associated system is currently under bidding stage with schedule as 18 months from SPV transfer.	
Neemuch PS	WR	66.5 GW REZ	MP				2x500MVA, 400/220kV			1000	500	500			Neemuch PS has been planned for evacuation of 1GW power from generation projects and associated transmission system is expected to be commissioned progressively by Feb'24. Presently, 500MW capacity has been allocated at Neemuch PS and 500MW margin is left.	
Mandsaur PS	WR	181.5 GW REZ	MP					3x1500MVA, 765/400kV	5x500MVA, 400/220kV	2000	0			2000	Mandsaur PS (near Neemuch) has been planned for evacuation of 2GW power from generation projects.	

Status of margins available at Existing / Under Construction / Planned ISTS RE Pooling Stations for proposed RE integration													All figures are in MW (as on 30-04-2023)			
Name of station	Region	RE PS Category	State	Transformation Capacity (MVA)						Pooling station capacity (MVA)	Capacity Allocated (MW)	Additional Margin on existing / UC system		Additional Margin with Planned/Future ICT/Line Augmentation		Remarks
				Existing		Under Implementation		Planned [Approved/Under Approval]				220kV level	400kV level	220kV level	400kV level	
				765/400kV	400/220kV	765/400kV	400/220kV	765/400kV	400/220kV							
Dhule PS	WR	181.5 GW REZ	Maharashtra						4x500MVA, 400/220kV (Under Bidding)	2000	0			2000		Dhule PS has been planned for evacuation of 2GW power from generation projects & is presently under bidding with implementation timeframe as 24 months from SPV transfer.
				<b>All India Total</b>						<b>138335</b>	<b>85066.2</b>	<b>21719</b>	<b>3000</b>	<b>14815</b>	<b>11995</b>	<b>51531</b>

**Note:**

Capacity allocated and margins indicated above are w.r.t connectivity at a particular pooling station. Evacuation of power to grid would depend on the development of transmission corridor identified with respective generation project.