

Clarification No.-I dated 05.01.2022 of the Bidding Document for Empanelment of Survey Agency on Rate Contract Basis for survey work using Modern Survey Techniques for route alignment of transmission line, identification of substation sites and preparation of report for transmission scheme allocated by National Committee on Transmission (NCT) which shall be used in selection of developer as Transmission Service Provider through Tariff Based Competitive Bidding process or any other survey work of transmission lines/ Sub-Stations

Specification No.: CTUIL/Survey/Empanelment/2021-22

Sl. No.	Clause Reference	Clause	Bidder's Queries	Clarification on queries
1	Terms of Payment, GCC Clause 3.2, Section-IV, Volume-I of Bidding Documents	<p>After the LOI has been issued by BPC for Transmission System under bidding to the successful developer for the Transmission System and the SPV has been handed over to the selected bidder.</p> <p>Or</p> <p>four months from the acceptance of Final Report of Survey by CTUIL, whichever is earlier.</p>	<p>Since the scope of agency will be completed after the acceptance and approval of final report.</p> <p>The payment linkage towards the issuance of LOI to the TSP looks not feasible.</p> <p>It is requested the payment may please be distributed among other 2 payment milestone.</p>	Provisions of Bidding Document shall prevail.
2	Technical Specification page no-4-point no.3, Volume-II of Bidding Documents	"Preparation of Survey Report including identification and explanation of route constraints like Forest, revenue area, protected area, wildlife infringement, Animal/Bird sanctuary, infringement of endangered species habitats, GIB area, vicinity to civil and defense Airports, major river/sea crossings & coal, mineral mining areas, oil pipe line/underground inflammable pipe lines, railway lines, canals, roads, defense setup etc., infrastructure details available enroute, various clearances required in the final route alignment, possible RoW constraint areas etc."	we wanted to know for identification of revenue area, protected forest land scheduling is required or not because if land scheduling has to be done than its has to be done for entire line which shoot's up the cost.	No land scheduling is required for submission to forest authorities at this stage.

Clarification No.-I dated 05.01.2022 of the Bidding Document for Empanelment of Survey Agency on Rate Contract Basis for survey work using Modern Survey Techniques for route alignment of transmission line, identification of substation sites and preparation of report for transmission scheme allocated by National Committee on Transmission (NCT) which shall be used in selection of developer as Transmission Service Provider through Tariff Based Competitive Bidding process or any other survey work of transmission lines/ Sub-Stations

Specification No.: CTUIL/Survey/Empanelment/2021-22

3	Technical Specification page no-4-point no.3, Volume-II of Bidding Documents	Initiation of any forest clearance based on survey of final route alignment with the concerned Authorities."	we wanted to know that only identification of DFO we have to done or we have to take clearance from forest department because it will take time, cost and many other documents which are not mentioned in this RFP.	Identification of forest authorities and the forest is required at this stage.
4.	Annexure A(QR) Clause 1.1	Technical Requirements/ Experience: The qualification of bidder will be based on meeting the minimum criteria specified below regarding bidder's technical experience: The bidder should have successfully completed, as a prime contractor, the work of route alignment using remote sensing techniques (satellite imageries), digitization of profile and optimization of minimum 500 km transmission line of 220kV or above in maximum 5 no. of projects during the previous five (5) financial years. Out of 500 km, survey of 250 km of transmission line must be for 400 kV or above.	We request the experience for evaluation may please be considered for the last 10 years for similar projects	Provisions of Bidding Document shall prevail.