

ATC-TTC for March'2015

Issue Date: 22-03-2015

Revision No. 2

Corridor	Total Transmission Capacity (TTC) (MW)	Transmission Reliability Margin (TRM) (MW)	Available Transfer Capacity (ATC) (MW)	Comments
ER-NER	740	40	700	Considering High dispatch at Farakka & Low Hydro Condition

Limiting Constraint

ER-NER corridor	Farakka – Malda 400kV D/c line (n-1)
-----------------	--------------------------------------

Note:

- 1. The above values are indicative. Based on studies carried on receipt of LTA Applications or MTOA application, margins may vary depending upon the injection and drawl points. Accordingly, the LTA/MTOA shall be dealt based on the studies.*
- 2. TTC/ATC for ER-NER corridor is sensitive to Generation available at Farakka and hydro generation available in Bhutan and Sikkim.*